


Rural Water Supply & Sanitation Engineering Department
Chemical analysis Report


Office of the
Executive Engineer MB Intra Division
MANCHERIAL

1 Name of the Laboratory : Water Quality Monitoring Laboratory, Mancherial
2 Name of the Division : Mancherial
3 Name of the District : Mancherial

Sl. No	Date	Mandal	Gram panchayat	Habitation	Location	Source	5	5	6.5 to 8.5	500	200	300	75	30	250	1.0	45	200	0.3	Remarks
							25	10	No relation	2000	600	600	200	100	1000	1.5	45	400	1.0	
							Colour	Turbidity	PH	Total Dissolved Solids mg / lit.	Alkalinity(Methyl orange) mg/lit.	Total Hardness mg / lit.	Calcium (As Ca) mg/lit.	Magnesium (As Mg) mg/lit.	Chloride (As Cl) mg/lit.	Fluoride (As F) mg/lit.	Nitrate (No3) mg/lit.	Sulphate (As So4) mg/lit.	Iron (As Fe) mg/lit.	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	22
1	27 03.2025	Mancherial	Mancherial	Mancherial	Sri Ushodaya High School	Bore Water (Raw Water)	Nil	Nil	7.4	1127	368	300	112	45 12	298	0.2	0	78	0.2	Satisfactory
1	27 03.2025	Mancherial	Mancherial	Mancherial	Sri Ushodaya High School	Filter Water	Nil	Nil	6.9	63	28	20	8	2.88	15	0.2	0	8	0.1	Satisfactory


Asst. Chemist
RWS&S Division, Mancherial


MANAGER
SRI USHODAYA HIGH SCHOOL
Mancherial, Telangana.


PRINCIPAL
SRI USHODAYA HIGH SCHOOL
MANCHERIAL-504 208.
Dist: Mancherial. T.S.


Rural Water Supply & Sanitation Engineering Department
Bacteriological Analysis Report


Office of the
Executive Engineer MB Intra Division
MANCHERIAL

1 Name of the Laboratory : Water Quality Monitoring Laboratory,Mancherial.
2 Name of the Division : Mancherial
3 Name of the District : Mancherial

Sl. No	Date of Collection	Mandal	Gram panchayat	Habitation	Location	Source	Address of sender	Sample Collected by	Time of collection	MPN Count	E.Coli	Remarks
1	2	3	4	5	6	7	8	9	10	11	12	13
1	27.03.2025	Mancherial	Mancherial	Mancherial	Sri Ushodaya High School	Bore Water (Raw Water)	Principal		11.40 AM	Nil	Nil	Satisfactory
2	27.03.2025	Mancherial	Mancherial	Mancherial	Sri Ushodaya High School	Filter Water	Principal		11.50 AM	Nil	Nil	Satisfactory


Microbiologist
RWS&S Division,Mancherial


MANAGER
SRI USHODAYA HIGH SCHOOL
Mancherial, Telangana.


PRINCIPAL
SRI USHODAYA HIGH SCHOOL
MANCHERIAL-504 208.
Dist: Mancherial. T.S.



OFFICE OF THE DEPUTY EXECUTIVE ENGINEER PUBLIC HEALTH SUB DIVISION

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 19/DEE/PH/SD/Mncl/Certificates/2024-25/207

Date: 29-03-2025

It is certified that an inspection team headed by Deputy Executive Engineer from Public Health Sub Division Mancherial (Name of Department/ Office) inspected the SRI USHODAYA HIGH SCHOOL, A.C.C. Quarry Road, Mancherial, Dist. Mancherial, Telangana – 504208 on 27-03-2025 (Date of inspection) and found that the SRI USHODAYA HIGH SCHOOL has safe drinking water facilities for the Students and members of staff of the institution and is maintaining the hygienic sanitation Condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one year from the date of issue.

[Handwritten Signature]
Deputy Executive Engineer
Public Health Sub Division
Mancherial
29/3/25

To
SRI USHODAYA HIGH SCHOOL,
ACC Quarry Road Mancherial,
Dist: Mancherial,
Telangana – 504 208.

[Handwritten Signature]
MANAGER
SRI USHODAYA HIGH SCHOOL
Mancherial, Telangana.

[Handwritten Signature]
PRINCIPAL
SRI USHODAYA HIGH SCHOOL
MANCHERIAL-504 208.
Dist: Mancherial. T.S.

OFFICE OF THE MANCHERIAL MUNICIPAL CORPORATION
DIST: MANCHERIAL

SANITARY CERTIFICATE

FILE NO. F1/1037/2025

Dated: 27/03/2025

Based on the report of concerned Sanitary Inspector, it is to certify the Sanitary Conditions of premises at **ACC Quarry Road, Mancherial**. In which **"SRI USHODAYA HIGH SCHOOL, MANCHERIAL, TELANGANA"** is found satisfactory. The School building is located in the Health surroundings. The certificate is valid for the financial year 2024-2025 only.

Terms & Conditions:

1. Complete plastic ban should be enforced.
2. Minimum greenery need to be maintained.
3. Rain Water harvesting system should be established.
4. Proper dustbins should be maintained for wet & dry waste.
5. Running water should be provided in all toilets & should be clean.
Unlocked and functional at all the time.
6. Proper drinking water facility (Preferably cold water in summer) at multiple places should be provided.

The given Sanitary Certificate is issued subject to fulfillment of above conditions any deviation will invite cancellation of given Sanitary Certificate.

Shiveji

Commissioner

Mancherial Municipal Corporation

(Signature)

To.
PRINCIPAL,
SRI USHODAYA HIGH SCHOOL,
ACC QUARRY ROAD, MANCHERIAL.

(Signature)
MANAGER
SRI USHODAYA HIGH SCHOOL
Mancherial, Telangana.

Y. Balaji
PRINCIPAL
SRI USHODAYA HIGH SCHOOL
MANCHERIAL-504 208.
Dist: Mancherial, T.S.

